






Test Report issued under the responsibility of:



| | |
|---|---|
| TEST REPORT IEC 60947-5-1 Part 5: Control circuit devices and switching elements Electromechanical control circuit devices | |
| Report Number | 180600074SHA-003 |
| Date of issue | 2018-10-08 |
| Total number of pages..... | 31 |
| Name of Testing Laboratory preparing the Report..... | Intertek Testing Services Shanghai Building No.86, 1198 Qinzhou Road (North), Shanghai 200233, China |
| Applicant's name..... | Elmark Industries SC |
| Address | 2 Dobrudzha blvd., Dobrich, BULGARIA |
| Test specification: | |
| Standard | IEC 60947-5-1:2016 |
| Test procedure | CB Scheme |
| Non-standard test method..... | N/A |
| Test Report Form No..... | IEC60947_5_1E |
| Test Report Form(s) Originator..... | DEKRA Certification B.V. |
| Master TRF | Dated 2017-10-06 |
| Copyright © 2017 IEC System of Conformity Assessment Schemes for Electrotechnical Equipment and Components (IECEE System). All rights reserved. This publication may be reproduced in whole or in part for non-commercial purposes as long as the IECEE is acknowledged as copyright owner and source of the material. IECEE takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context. If this Test Report Form is used by non-IECEE members, the IECEE/IEC logo and the reference to the CB Scheme procedure shall be removed. This report is not valid as a CB Test Report unless signed by an approved CB Testing Laboratory and appended to a CB Test Certificate issued by an NCB in accordance with IECEE 02. | |
| General disclaimer: | |
| The test results presented in this report relate only to the object tested. This report shall not be reproduced, except in full, without the written approval of the Issuing CB Testing Laboratory. The authenticity of this Test Report and its contents can be verified by contacting the NCB, responsible for this Test Report. | |
| Test item description | Auxiliary contacts |
| Trade Mark |  |
| Manufacturer..... | Same as applicant |
| Model/Type reference | LT1-D4011, LT1-D5011, LT1-D6511, LT1-D8011, LT1-D9511 |
| Ratings | See general product information (page 6) |

| | | |
|---|--|---|
| Responsible Testing Laboratory (as applicable), testing procedure and testing location(s): | | |
| <input checked="" type="checkbox"/> | Testing Laboratory: | Intertek Testing Services Shanghai |
| Testing location/ address.....: | | Building No.86, 1198 Qinzhou Road (North), Shanghai 200233, China |
| <input checked="" type="checkbox"/> | Associated Testing Laboratory: | Inspection Center of Products' Quality of Low Voltage |
| Testing location/ address.....: | | Electric Apparatus in Zhejiang Province West Zhonghuan Road, Jiaxing City, Zhejiang Province, P.R.China |
| Tested by (name, function, signature).....: | | Allen Wang  |
| Approved by (name, function, signature)....: | | Quiet Lin  |
| <input type="checkbox"/> | Testing procedure: CTF Stage 1: | |
| Testing location/ address.....: | | |
| Tested by (name, function, signature).....: | | |
| Approved by (name, function, signature)....: | | |
| <input type="checkbox"/> | Testing procedure: CTF Stage 2: | |
| Testing location/ address.....: | | |
| Tested by (name + signature).....: | | |
| Witnessed by (name, function, signature)..: | | |
| Approved by (name, function, signature)....: | | |
| <input type="checkbox"/> | Testing procedure: CTF Stage 3: | |
| <input type="checkbox"/> | Testing procedure: CTF Stage 4: | |
| Testing location/ address.....: | | |
| Tested by (name, function, signature).....: | | |
| Witnessed by (name, function, signature)..: | | |
| Approved by (name, function, signature)....: | | |
| Supervised by (name, function, signature) : | | |

Summary of testing:

| Clause | Testing items | Testing location |
|-----------------|--|------------------|
| 8.3.3.2 | Operating limits of contactor relays | CBTL |
| 8.3.3.3 | temperature rise | ACTL |
| 8.3.3.4 | Dielectric properties | ACTL |
| 8.2.4 of part 1 | Mechanical properties of terminals | CBTL |
| 8.3.3.5.2 | Making and breaking capacities of switching elements under normal conditions | ACTL |
| 8.3.3.5.5b | Dielectric verification | CBTL |
| 8.3.3.5.3 | Making and breaking capacities of switching elements under abnormal conditions | ACTL |
| 8.3.3.5.5b | Dielectric verification | CBTL |
| 8.3.4 | Performance under conditional short-circuit current | ACTL |
| 8.3.3.5.5b | Dielectric verification | CBTL |

Tests performed on auxiliary circuit according to IEC/EN 60947-5-1:

| 180600074SHA- 003 | Type | Seq. I | Seq. II | Seq. III | Seq. IV | Seq. V | Seq. VI |
|----------------------|-----------|--------|---------|----------|---------|--------|---------|
| | LT1-D9511 | 1 | 1 | 1 | 1 | - | - |

Summary of compliance with National Differences :

The products comply with the standard EN 60947-5-1: 2017

Copy of marking plate:

See report: 180600074SHA-001, -002

| | |
|--|--|
| Test item particulars | |
| Classification of installation and use | Auxiliary circuit of Contactor |
| Supply Connection..... | Cable connection |
| Kind of control circuit device..... | <input type="checkbox"/> manual control switches, e.g. push-buttons, rotary switches, foot switches, etc. <input checked="" type="checkbox"/> electromagnetically operated control switches, either time delayed or instantaneous, e.g. contactor relays <input type="checkbox"/> pilot switches, e.g. pressure switches, temperature sensitive switches (thermostats) <input type="checkbox"/> position switches <input type="checkbox"/> associated control equipment, e.g. indicator lights, etc. |
| Kind of switching elements | <input checked="" type="checkbox"/> auxiliary contacts of a switching device (e.g. contactor, circuit-breaker, etc) which are not dedicated exclusively for use with the coil of that device <input type="checkbox"/> interlocking contacts of enclosure doors <input type="checkbox"/> control circuit contacts of rotary switches <input type="checkbox"/> control circuit contacts of overload relays |
| Number of poles..... | 1NC+1NO |
| Kind of current..... | <input checked="" type="checkbox"/> ac and/or <input checked="" type="checkbox"/> dc |
| Interrupting medium..... | <input checked="" type="checkbox"/> air, <input type="checkbox"/> oil, <input type="checkbox"/> gas, <input type="checkbox"/> vacuum, <input type="checkbox"/> ... |
| Operating conditions | |
| Method of operations | <input type="checkbox"/> manual <input checked="" type="checkbox"/> electromagnetic <input type="checkbox"/> pneumatic <input type="checkbox"/> electro-pneumatic |
| Method of control | <input checked="" type="checkbox"/> automatic <input type="checkbox"/> non-automatic <input type="checkbox"/> semi-automatic |
| Rated and limiting values for switching elements: | |
| Voltages: | |
| - rated operational voltage U_e (V) | 415 |
| - rated insulation voltage U_i (V) | 690 |
| - rated impulse withstand voltage U_{imp} (kV) | 6 |
| Currents: | |
| - conventional free air thermal current I_{th} (A) | 10 |
| - conventional enclosed thermal current I_{the} (A)..... | N/A |
| - rated operational current I_e (A) | 0,95 |
| Rated frequency (Hz)..... | 50/60 |
| Utilization category..... | AC-15 |
| Short-circuit characteristic: | |

| | |
|--|-------------------------|
| - rated conditional short-circuit current (kA) | 1kA |
| - kind of protective device | Fuse, RT16-00, 10A/500V |
| Electrically separated contact elements..... | Yes |
| Actuating quantities for pilot switches | N/A |
| Pilot switches having two or more contact elements.... | N/A |
| Indication of contact elements of same polarity..... | N/A |
| IP code, in case of an enclosed control device | IP 20 |
| Pollution degree | 3 |
| Suitability for isolation, with the symbol 07-13-06 of IEC 60617-7 | N/A |

| | |
|---|----------|
| Possible test case verdicts: | |
| - test case does not apply to the test object | N/A |
| - test object does meet the requirement | P (Pass) |
| - test object does not meet the requirement | F (Fail) |

| | |
|---------------------------------------|-------------------------------|
| Testing..... | |
| Date of receipt of test item..... | 2018-06-12 |
| Date (s) of performance of tests..... | From 2018-06-12 to 2018-08-05 |

General remarks:

"(See Enclosure #)" refers to additional information appended to the report.
 "(See appended table)" refers to a table appended to the report.
 This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program
Throughout this report a comma / point is used as the decimal separator.

The test report shall be used in conjunction with reports: 180600074SHA-001, -002

| | |
|--|--|
| Manufacturer's Declaration per sub-clause 4.2.5 of IEC 60947-2: | |
| The application for obtaining a CB Test Certificate includes more than one factory location and a declaration from the Manufacturer stating that the sample(s) submitted for evaluation is (are) representative of the products from each factory has been provided : | <input type="checkbox"/> Yes <input checked="" type="checkbox"/> Not applicable |
| When differences exist; they shall be identified in the General product information section. | |
| Name and address of factory (ies) : Same as applicant | |
| General product information: Control circuit: Us= 415V~ Auxiliary circuit: Ith= 10A, Cat.: AC-15, Ue= 415V, Ie= 0,95A The auxiliary circuits of LT1-D4011, LT1-D5011, LT1-D6511, LT1-D8011 are identical to LT1-D9511, all tests are performed on LT1-D9511. | |

| IEC 60947-5-1 | | | |
|---------------|---|-------------------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 5 | PRODUCT INFORMATION | | |
| 5.2 | Marking | | |
| | Data shall be preferably marked on the equipment: | | |
| | a - manufacturer's name or trademark | ELMARK | P |
| | b - type designation or serial number | LT1 Series | P |
| | Data shall be included on the nameplate, or on the equipment, or in the manufacturer's published literature: | | P |
| | c - number of this standard | IEC/EN 60947-5-1 | P |
| | d - rated operational voltages | AC: 415V | P |
| | e - utilization category and rated operational currents, at the rated operational voltages of the control circuit device | AC-15: 0,95A | P |
| | f - rated insulation voltage: | 690V | P |
| | g - rated impulse withstand voltage | 6kV | P |
| | h - vacant | | N/A |
| | i - IP code, in case of enclosed control circuit device | | N/A |
| | j - pollution degree | 3 | P |
| | k - type and maximum ratings of short-circuit protective device | Fuse, RT16-00, 10A/500V | P |
| | l - conditional short-circuit current | 1kA | P |
| | m - suitability for isolation, where applicable, with the symbol S00288 of IEC 60617 | | N/A |
| | n - indication of contact elements of same polarity | | N/A |
| | Marking of data under n) shall be included on the nameplate of the control circuit device in order to ensure proper wiring at installation. | | N/A |
| | o) length of insulation to be removed before insertion of the conductor into the terminal. | | N/A |
| | p) for non-universal screwless terminals: <ul style="list-style-type: none"> – "s" or "sol" for terminals declared for rigid-solid conductors; – "r" for terminals declared for rigid (solid and stranded) conductors; – "f" for terminals declared for flexible conductors. | | N/A |
| | The indication "s", "sol", "r" or "f" for non-universal screwless terminals shall be marked on the device or, if the space available is not sufficient, on the smallest package unit or in technical information provided with the product. | | N/A |
| 5.2.2 | Terminal identification and marking (see 7.1.8.4 of IEC 60947-1) | | |
| | Clearly and permanently identified according IEC 60445 and Annex L, unless superseded by relevant standard. | | P |

| IEC 60947-5-1 | | | |
|---------------|---|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | Neutral terminal identified by letter : | | N/A |
| | Protective earth terminal identified by letter | | N/A |
| 5.2.3 | Functional markings | | |
| | Actuators may be identified by symbols in the form of engravings, but if a stop button carries any symbol engraved or marked this symbol shall be a circle or oval | | N/A |
| | Letters or words may used where space is available | | N/A |
| | Symbols shall be in accordance with IEC 60417 | | N/A |
| 5.2.4 | Emergency stop | | |
| | Actuator shape and colour, background colour and direction of unlatching for emergency stop devices with mechanical latching function shall be in accordance with 4.2 of IEC 60947-5-5 | | N/A |
| 5.2.5 | Operating diagram | | |
| 5.2.5.1 | General | | |
| | As rotary switches may have multiplicity of contacts elements and a multiplicity of actuator positions, it necessary that the manufacturer indicates the relationship between the actuator positions and the associated contact elements position | | N/A |
| 5.2.5.2 | Position indication and contact position | | |
| | Sub clause 7.1.6.1 of IEC 60947-1 applies | | N/A |
| | The position indication shall be clear, and the associated text or symbols shall be indelible and easily legible | | N/A |
| 5.2.5.3 | Terminal markings for operating diagrams | | |
| | Terminal markings shall be clearly identifiable with respect to the operating diagram (see also Annex M) | | N/A |
| 5.2.6 | Time delay markings | | |
| | The manufacturer shall indicate, for each time-delay contact element, the characteristic of the delay, according to 2.4.1.1 or 2.4.1.2 | | N/A |
| 5.3 | Instructions for installation, operation and maintenance | | |
| | The manufacture shall specify, in his documents or catalogues: | | |
| | - the conditions for installation, operation and maintenance, if any, of the equipment during operation and after a fault | | P |
| | - the specify the measures to be taken with regard to EMC, if any, | | N/A |

| IEC 60947-5-1 | | | |
|---------------|---|---|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | - equipment only suitable in environment A shall provided with the following notice | NOTICE This product has been designed for environment B may cause unwanted electromagnetic disturbances in which case the user may be required to take adequate mitigation measures. | N/A |
| | - if necessary, the instructions for transport, installation and operation of the equipment shall indicate the measures that are particular importance for the proper and correct installation, commissioning and operation of the equipment. | | P |

| 6 | Normal service, mounting and transport conditions | | |
|---------|--|-----|-----|
| 6.1.1 | Ambient temperature | | |
| | Ambient air temperature does not exceed +40 °C and its average over 24 hours does not exceed +35°C and the lower limit is -5°C | | P |
| 6.1.2 | Altitude | | |
| | Altitude of side of installation does not exceed 2000m | | P |
| 6.1.3 | Atmospheric conditions | | |
| 6.1.3.1 | Relative humidity does not exceed 50 % at max temp +40 °C, higher rel. hum may at lower temperatures e.g. 90% at +20 °C | | P |
| 6.1.3.2 | Pollution degree | | |
| | Unless otherwise stated, equipment for: - industrial use shall have a degree 3, depending upon micro-environment - household and similar shall have degree 2 | 3 | P |
| 6.1.4 | Shock and vibration | | |
| | Under consideration | | N/A |
| 6.2 | Conditions during transport and storage | | |
| | Under consideration | | N/A |
| 6.3 | Mounting | | |
| | Accordinging manufacturer's instruction | see | N/A |
| 6.3.1 | Mounting of single hole mounted devices | | |
| | Dimensions according Table 2 | | N/A |
| 6.3.1.1 | Location of key recess (if any) | | |
| | Dimensions according Table 3 | | N/A |
| 6.3.1.2 | Range of panel thickness | | |
| | The device shall be capable of being mounted on any thickness between 1 and 6 mm | | N/A |
| 6.3.1.3 | Grouping of devices | | |

| IEC 60947-5-1 | | | |
|---------------|--|-----------------------------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | The distances a between the mounting centres in the same row and b between the centre lines of the rows shall be not less than those given in table 3. Distances a and b may be interchanged | | N/A |
| 7 | CONSTRUCTIONAL AND PERFORMANCE REQUIREMENTS | | |
| 7.1 | Constructional requirements | | |
| 7.1.1 | General | | |
| | Sub clause 7.1 of IEC 60947-1 applies except for 7.1.2, 7.1.3, 7.1.7, 7.1.9 and 7.1.13, and with the following additions: | | |
| 7.1.2 | Materials | | |
| 7.1.2.2 | Glow-wire testing | | |
| | | See report:180600074SHA-001, -002 | P |
| 7.1.2.3 | Test based on flammability category | | |
| | | See Table | N/A |
| 7.1.3 | Current-carrying parts and their connection | | |
| | No contact pressure through insulating materials | | P |
| 7.1.4 | Clearances and creepage distances | | |
| | Clause 7.1.4 of IEC 60947-1 applies | | |
| | Clearances | | |
| | Minimum values are given in Table 13 and Table 15 of IEC 60947-1 | | |
| | Rated impulse withstand voltage | 6kV | |
| | Minimum clearance - Case B (mm) | Required : __ mm | |
| | Minimum clearance - Case A (mm) | Required : 5,5 mm | |
| | Measured clearances (mm) | Measured: .8,0 mm | P |
| | Creepage distances | | |
| | Pollution degree | 3 | |
| | Comparative tracking index (V) | 175 | |
| | Material group | IIIa | |
| | Rated insulation voltage Ui (V) | 690 | |
| | Minimum creepage distances (mm) | 10,0 | |
| | Measured creepage distances (mm) | >15 | P |
| 7.1.5 | Actuator | | |
| 7.1.5.1 | Insulation | | |
| | Clause 7.1.5.1 of IEC 60947-1 applies | | N/A |
| 7.1.5.2 | Direction | | |
| | Clause 7.1.5.2 of IEC 60947-1 applies | | N/A |
| 7.1.5.3 | Actuating force (or moment) | | |

| IEC 60947-5-1 | | | |
|---------------|---|---|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | | See test sequence V | N/A |
| 7.1.5.4 | Limitation of rotation (of rotary switch) | | |
| | When actuators with limited or unidirectional movement are used, they shall be fitted with robust means of limitation, capable of withstanding five times the actual maximum actuating moment. | | N/A |
| 7.1.5.5 | Emergency stop | | |
| | The actuator shall preferably latch in the actuated position with the control contact open. This latching shall be released by a separate action, e.g. by pulling, rotation, or by means of a key. | | N/A |
| 7.1.6 | Indication of the contact position | | |
| | Clause 7.1.6 of IEC 60947-1 applies | | N/A |
| 7.1.7 | Conditions for control switches suitable for isolation | | |
| | A control switch suitable for isolation shall be manually operated with a direct opening action (see Annex K) and shall comply with the isolating function in the open position (see 2.1.19 and 7.1.7 of IEC 60947-1). | | N/A |
| | The open position of a control switch suitable for isolation shall be a position in which the switch can remain when no actuating force is applied. | | N/A |
| | In order to avoid unintentional reclosing, it shall be possible to prevent the operation of the control switches suitable for isolation when the contact elements are in the open position. This may be obtained by padlocking or by a latch which shall only be releasable by a special tool or key. | | N/A |
| 7.1.8 | Terminals | | |
| | | See clause 8.2.4 | P |
| 7.1.10 | Provisions for protective earthing | | |
| | Clause 7.1.10 of IEC 60947-1 applies | | N/A |
| 7.1.11 | Enclosures for equipment | | |
| | Clause 7.1.11 of IEC 60947-1 applies | | N/A |
| 7.1.12 | Degree of protection of enclosed equipment | | |
| | Degree of protection : IP20 | | |
| | Test for first characteristic | | |
| | Test for first numeral : | <input type="checkbox"/> 1: <input checked="" type="checkbox"/> 2: <input type="checkbox"/> 3: <input type="checkbox"/> 4: <input type="checkbox"/> 5: <input type="checkbox"/> 6: | P |
| | Test for second characteristic | | |

| IEC 60947-5-1 | | | |
|---------------|---|--|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | Test for second numeral : | <input type="checkbox"/> 1: <input type="checkbox"/> 2: <input type="checkbox"/> 3: <input type="checkbox"/> 4: <input type="checkbox"/> 5: <input type="checkbox"/> 6: <input type="checkbox"/> 7: <input type="checkbox"/> 8: | N/A |
| 7.1.14 | Class II control circuit devices | | |
| | These devices shall not be provided with means for protective earthing (see IEC 61140) | | N/A |
| | For class II control circuit devices insulated by encapsulation, see Annex F | See annex F | |
| 7.1.15 | Requirements for control devices with integrally connected cables | | |
| | | See annex G | N/A |
| 7.2 | Performance requirements | | |
| | Subclauses 7.2.1.1 and 7.2.2 of IEC 60947-1 apply with the following additions: | | |
| 7.2.1.2 | Limits of operation of contactor relays | | |
| | The limits of operation for contactor relays shall be in accordance with IEC 60947-4-1 | See clause 8.3.3.2 | P |
| 7.2.3 | Dielectric properties | | |
| | Subclause 7.2.3 of IEC 60947-1 applies with the following addition | See clause 8.3.3.4 | P |
| | For class II control circuit devices insulated by encapsulation | See Annex F | N/A |
| 7.2.4 | Ability to make and break under normal and abnormal load conditions | | |
| 7.2.4.1 | Making and breaking capacities | | |
| | Making and breaking capacities under normal conditions as state in table 4 | See clause 8.3.3.5.2 | P |
| | Making and breaking capacities under abnormal conditions as state in table 5 | See clause 8.3.3.5.3 | P |
| 7.2.4.3 | Durability | | |
| | Sub-clause 7.2.4.3 of IEC 60947-1 applies with the following additions: | | |
| | Mechanical durability | See Annex C | N/A |
| | Electrical durability | See Annex C | N/A |
| 7.2.5 | Conditional short-circuit current | | |
| | The switching element shall withstand the stresses resulting from short-circuit current under the conditions specified in 8.3.4 | | P |
| 7.2.7 | Additional requirements for control switches suitable for isolation | | |

| IEC 60947-5-1 | | | |
|---------------|---|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | Control switches suitable for isolation shall be tested according to 8.3.3.4 of IEC 60947-1 with a value of test voltage as specified in Table 14 or IEC 60947-1 corresponding to the rated impulse withstand voltage U_{imp} declared by the manufacturer. | | N/A |
| | Other additional requirements applicable to such control switches are under consideration | | N/A |
| 7.2.8 | Maximum recovery time | | |
| | For equipment incorporating electronic circuits the maximum recovery time and the measuring method shall be stated by the manufacturer | | N/A |
| 7.3 | Electromagnetic compatibility (EMC) | | |
| | Subclause 7.3 of IEC 60947-1 applies with the following additions: | | N/A |
| | The control circuit device to be tested shall have all the essential design details of the type which it represents and shall be in a clean and new condition. | | N/A |
| | The EMC tests shall be conducted at rated operational voltage U_e , or if the rated operational voltage is given as a range, then the test shall be conducted at a voltage which represents the worst case condition. | | N/A |
| | Maintenance or replacement of parts during or after a testing cycle is not permitted. | | N/A |
| | The products covered by this standard are intended for use in environment A. | | N/A |
| | Contactors incorporating electronic circuits shall follow the requirements of 8.3.2.2 of IEC 60947-4-1 | | N/A |

| IEC 60947-5-1 | | | |
|----------------|--|--|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 8.3.1 | TEST SEQUENCE I (-1 sample: LT1-D9511) | | |
| Test No. 1 | - operating limits of contactor relays (8.3.3.2) | | |
| Test No. 2 | - temperature rise (Clause 8.3.3.3.) | | |
| Test No. 3 | - dielectric properties (Clause 8.3.3.4) | | |
| Test No. 4 | - mechanical properties of terminals (8.2.4 of IEC 60947-1) | | |
| 8.3.3.2 | Operating limits of contactor relays | | |
| 9.3.3.2.1 | Power-operated equipment: | | |
| 8.2.1.2.1 | Electromagnetic contactors and starters | | |
| | rated control supply voltage U_s (V) | See result in test report: 180600074SHA-001, -002 | |
| | frequency (Hz) | | |
| | declared ambient temperature(>40 °C) for 100% U_s | | |
| | limits of close satisfactorily at any value between 85% and 110% of rated control supply voltage U_s . : | | N/A |
| | limits of drop out and open fully are: 75% to 20% for a.c. and 75% to 10% for d.c. : | | N/A |
| | ambient temperature(-5 °C) for 100% U_s | | |
| | limits of close satisfactorily at any value between 85% and 110% of rated control supply voltage U_s . : | | N/A |
| | Limits of drop out and open fully are: 75% to 20% for a.c. and 75% to 10% for d.c. : | | N/A |
| 8.2.1.2.2 | Contactors and starters with electronically controlled electromagnet | | |
| | Rated control supply voltage U_s (V) | | |
| | Frequency (Hz) | | |
| | Declared ambient temperature(>40 °C) for 100% U_s | | |
| | Limits of close satisfactorily at any value between 85% and 110% of rated control supply voltage U_s . : | | N/A |
| | Limits of drop out and open fully are: 75% to 20% for a.c. and 75% to 10% for d.c. : | | N/A |
| | Ambient temperature(-5 °C) for 100% U_s | | |
| | Limits of close satisfactorily at any value between 85% and 110% of rated control supply voltage U_s . : | | N/A |
| | Limits of drop out and open fully are: 75% to 20% for a.c. and 75% to 10% for d.c. : | | N/A |
| 8.2.1.2.3 | Electro-pneumatic contactors and starters | | |
| | Rated air supply pressure(Bar) | | |
| | Declared ambient temperature(>40 °C) for 100% of the rated air supply pressure(Bar) | | |

| IEC 60947-5-1 | | | |
|---------------|---|--|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | Limits of close satisfactorily at any value between 85% and 110% of rated air supply pressure(Bar) .. : | | N/A |
| | Limits of drop out and open fully are: 75% to 10% of rated air supply pressure(Bar) .. : | | N/A |
| | Ambient temperature(-5 °C) for 100% of the rated air supply pressure(Bar) | | |
| | Limits of close satisfactorily at any value between 85% and 110% of rated air supply pressure(Bar) .. : | | N/A |
| | Limits of drop out and open fully are: 75% to 10% for the rated air supply pressure(Bar) .. : | | N/A |
| 8.3.3.3 | Temperature rise | | |
| | ambient temperature 10-40 °C .. : | See result in test report: 180600074SHA-001, -002 | |
| | test enclosure W x H x D (mm x mm x mm) .. : | - | |
| | material of enclosure .. : | - | |
| | NO-contacts, test conditions: | | |
| | - rated operational current I _e (A) .. : | | |
| | - conventional free air thermal current I _{th} (A) .. : | | |
| | - cable cross-section (mm ²) .. : | | |
| | - cable length (m) .. : | | |
| | - temperature rise of NO terminals (K) .. : | | N/A |
| | NC-contacts, test conditions: | | |
| | - rated operational current I _e (A) .. : | | |
| | - cable cross-section (mm ²) .. : | | |
| | - cable length (m) .. : | | |
| | - temperature rise of NC terminals (K) .. : | | N/A |
| | Coils and electromagnets, test conditions: | | |
| | - rated control supply voltage U _s (V / Hz) .. : | | |
| | - Class of insulating material .. : | | |
| | - temperature rise of coil and electromagnets (K) ... : | See table | N/A |
| 8.3.3.4 | Dielectric properties | | |
| | Test of dielectric properties, impulse withstand voltage (U_{imp} indicated): | | |
| | - verification by measurement of clearances instead of testing | | |
| | - rated impulse withstand voltage (kV) .. : | 6 | |
| | - test U _{imp} auxiliary circuits (kV) .. : | 7,3 | P |
| | Test of dielectric properties, dielectric withstand voltage (U_{imp} not indicated): | | |
| | - rated insulation voltage (V) .. : | | |
| | - control and auxiliary circuits, test voltage (V) for 60 sec .. : | | N/A |

| IEC 60947-5-1 | | | |
|---------------|---|---------------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 8.2.4 | Mechanical and electrical properties of terminals | | |
| 8.2.4.2 | Mechanical strength of terminals | | |
| | maximum cross-sectional area of conductor (mm ²) : | 2,5 mm ² | |
| | diameter of thread (mm) | 3,4 mm | |
| | torque (Nm) | 0,8 Nm | |
| | 5 times on 2 separate clamping units | | P |
| 8.2.4.3 | Testing for damage to and accidental loosening of conductor (flexion test) | | |
| | conductor of the smallest cross-sectional area (mm ²) | 1,0 mm ² | |
| | number of conductor of the smallest cross section . : | 2 | |
| | diameter of bushing hole (mm) | 6,4 mm | |
| | height between the equipment and the platen (mm) | 260 mm | |
| | mass at the conductor(s) (kg) | 0,4 kg | |
| | 135 continuous revolutions: the conductor shall neither slip out of the terminal nor break near the clamping unit | | P |
| 8.2.4.4 | Pull-out test | | |
| | force (N) | 35 | |
| | 1 min, the conductor shall neither slip out of the terminal nor break near the clamping unit | | P |
| 8.2.4.3 | Flexion test | | |
| | conductor of the largest cross-sectional area (mm ²) : | 2,5 mm ² | |
| | number of conductor of the largest cross-section ... : | 1 | |
| | diameter of bushing hole (mm) | 9,5 mm | |
| | height between the equipment and the platen (mm) | 280 mm | |
| | mass at the conductor(s) (kg) | 0,7 kg | |
| | 135 continuous revolutions: the conductor shall neither slip out of the terminal nor break near the clamping unit | | P |
| 8.2.4.4 | Pull-out test | | |
| | force (N) | 50 | |
| | 1 min, the conductor shall neither slip out of the terminal nor break near the clamping unit | | P |
| 8.2.4.3 | Flexion test | | |
| | conductor of the largest and smallest cross-sectional area (mm ²) | 2,5/1,0 | |
| | number of conductor of the smallest cross sectional, number of conductor of the largest cross sectional . : | 1/2 | |

| IEC 60947-5-1 | | | |
|---------------|---|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | diameter of bushing hole (mm) | 9,5/6,5 | |
| | height between the equipment and the platen (mm) | 280/260 | |
| | mass at the conductor(s) (kg) | 0,7/0,4 | |
| | 135 continuous revolutions: the conductor shall neither slip out of the terminal nor break near the clamping unit | | P |
| 8.2.4.4 | Pull-out test | | |
| | force (N) | 50/35 | |
| | 1 min, the conductor shall neither slip out of the terminal nor break near the clamping unit | | P |
| 8.2.4.5 | Test for insertability of unprepared round copper conductors having the maximum cross-section | | |
| | The test shall be carried out using the appropriate gauge form A or form B specified in Table 7. | | N/A |
| | The measuring section of the gauge shall be able to penetrate freely into the terminal aperture to the full depth of the terminal (see also note to Table 7). | | N/A |
| | Alternatively, the test can be carried out by inserting the largest conductor of type and rated cross-section among those recommended by the manufacturer, the diameter of which corresponds to the theoretical diameter according to Table 7a, after the insulation has been removed and the end has been reshaped. The stripped end of the conductor shall be able to enter completely within the clamping unit aperture, without use of undue force. | | N/A |
| 8.2.4.7 | Electrical performance of screwless-type clamping units | | |
| | If terminals are used which are qualified according to IEC 60999-1 and the operating conditions of the terminals in the device are according to the operating conditions specified by the manufacturer of the terminals, then the test does not need to be performed. | | N/A |
| | Sub clause 8.2.4.7 of IEC 60947-1 applies with the following changes: | | N/A |
| | <ul style="list-style-type: none"> – The test shall be done on the connecting device equipped with the clamping units; – The number of specimens shall be at least 8; – The test shall be done as a single 8 test: <ul style="list-style-type: none"> • Eight clamping units shall be tested to the declared voltage drop; • If the number of failed clamping units does not exceed two, the test is considered passed. | | N/A |
| | test current (A) | | N/A |
| | voltage drop < 15 mV. (V)..... | | N/A |
| 8.2.4.8 | Ageing test for screwless-type clamping units | | |

| IEC 60947-5-1 | | | |
|---------------|---|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | If terminals are used which are qualified according to IEC 60999-1 and the operating conditions of the terminals in the device are according to the operating conditions specified by the manufacturer of the terminals, then the test does not need to be performed. | | N/A |
| | Subclause 8.2.4.8 of IEC 60947-1 applies with the following changes: | | N/A |
| | The test shall be done on the connecting device equipped with the clamping units. | | N/A |
| | test current (A) | | N/A |
| | maximum temperature for the temperature cycles shall be 40°C. Max. temperature (°C) | | N/A |
| | voltage drop \leq 22,5 mV or 1,5 times the value measured after the 24th cycle. (V) | | N/A |

| IEC 60947-5-1 | | | |
|--|---|----------------------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 8.3.1 | TEST SEQUENCE II (-1 sample: LT1-D9511) | | |
| Auxiliary Contact (NO), 1 sample: LT1-D9511 | | | |
| Test No. 1 | - Making and breaking capacities of switching elements under normal conditions (8.3.3.5.3) | | |
| Test No. 2 | - Dielectric verification (8.3.3.5.6.b) | | |
| 8.3.3.5.3 | Making and breaking capacities of switching elements under normal conditions | | |
| | contact element (figure / form) | Figure 4e)/ form Zb | |
| | contact polarity..... | - | |
| | utilization category (AC / DC)..... | AC-15 | |
| | rated operational voltage Ue (V) | 415V | |
| | rated operational current Ie (A) or power (kW) | 0,95A | |
| No.1 | - test voltage U/Ue = 1,1 (V) | L1: 457 L2: - L3: - | P |
| | - power factor/ time constant | L1: 0,31 L2: - L3: - | P |
| | - make operations: test current I/Ie=10 (A) | L1: 9,70 L2: - L3: - | P |
| | - break operations: test current I/Ie=1 (A) | L1: 0,97 L2: - L3: - | P |
| | - a.c. test: Inductor shunted by a resistor taking 3% of the total power consumed - d.c. test: test current increase from zero to steady-state value within limits of figure 9 | | |
| | - on-time (ms) | 340 | |
| | - operating cycles per minute | 6 | |
| | - number of operating cycles | 50 | |
| | - test voltage U/Ue = 1,0 (V) | L1: 417 L2: - L3: - | P |
| | - power factor/ time constant | L1: 0,31 L2: - L3: - | P |
| | - make operations: test current I/Ie=10 (A) | L1: 9,70 L2: - L3: - | P |
| | - break operations: test current I/Ie=1 (A) | L1: 0,97 L2: - L3: - | P |
| No. 2 | - on-time (ms) | 340 | |
| | - operating cycles per minute | Rapidly as possible (60) | |
| | - number of operating cycles | 10 | P |

| IEC 60947-5-1 | | | |
|---------------|--|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| No. 3 | - on-time (ms) | 291 | |
| | - operating cycles per minute | 60 | |
| | - number of operating cycles | 990 | P |
| No. 4 | - on-time (ms) | 291 | |
| | - operating cycles per minute | 6 | |
| | - number of operating cycles | 5000 | P |
| | Behaviour and condition during and after the test: | | |
| | - no electrical or mechanical failures | | P |
| | - no contact welding or prolonged arcing | | P |
| | - no blowing of the fusible element in the earth circuit | | P |
| 8.3.3.5.6.b | Dielectric verification: | | |
| | dielectric test voltage (V) 2 xUe with a min.of 1000V: | 1000 V | P |

| | | | |
|--|---|----------------------------|---|
| 8.3.3.5.3 | Making and breaking capacities of switching elements under normal conditions | | |
| Auxiliary Contact (NC), 1 sample: LT1-D9511 | | | |
| | contact element (figure / form) | Figure 4e)/ form Zb | |
| | contact polarity..... | - | |
| | utilization category (AC / DC)..... | AC-15 | |
| | rated operational voltage Ue (V) | 415V | |
| | rated operational current Ie (A) or power (kW) | 0,95A | |
| No.1 | - test voltage U/Ue = 1,1 (V) | L1: 457 L2: - L3: - | P |
| | - power factor/time constant..... | L1: 0,31 L2: - L3: - | P |
| | - make operations: test current I/Ie=10 (A) | L1: 9,70 L2: - L3: - | P |
| | - break operations: test current I/Ie=1 (A) | L1: 0,97 L2: - L3: - | P |
| | - a.c. test: Inductor shunted by a resistor taking 3% of the total power consumed - d.c. test: test current increase from zero to steady-state value within limits of figure 9 | | |
| | - on-time (ms) | 340 | |
| | - operating cycles per minute | 6 | |
| | - number of operating cycles | 50 | |
| | - test voltage U/Ue = 1,0 (V) | L1: 417 L2: - L3: - | P |

| IEC 60947-5-1 | | | |
|---------------|--|----------------------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | - power factor/time constant | L1: 0,31 L2: - L3: - | P |
| | - make operations: test current I/Ie=10 (A) | L1: 9,70 L2: - L3: - | P |
| | - break operations: test current I/Ie=1 (A) | L1: 0,97 L2: - L3: - | P |
| No. 2 | - on-time (ms) | 340 | |
| | - operating cycles per minute | Rapidly as possible (60) | |
| | - number of operating cycles | 10 | P |
| No. 3 | - on-time (ms) | 291 | |
| | - operating cycles per minute | 60 | |
| | - number of operating cycles | 990 | P |
| No. 4 | - on-time (ms) | 291 | |
| | - operating cycles per minute | 6 | |
| | - number of operating cycles | 5000 | P |
| | Behaviour and condition during and after the test: | | |
| | - no electrical or mechanical failures | | P |
| | - no contact welding or prolonged arcing | | P |
| | - no blowing of the fusible element in the earth circuit | | P |
| 8.3.3.5.6.b | Dielectric verification: | | |
| | dielectric test voltage (V) 2 xUe with a min.of 1000V: | 1000 V | P |

| IEC 60947-5-1 | | | |
|--------------------|---|----------------------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 8.3.1 | TEST SEQUENCE III | | |
| | -1 sample: III-1, AC-15, 415V/0,95A | | |
| Test No. 1 | - Making and breaking capacities of switching elements under abnormal conditions (8.3.3.5.4) | | |
| Test No. 2 | - Dielectric verification (8.3.3.5.6.b) | | |
| 8.3.3.5.4 | Making and breaking capacities of switching elements under abnormal conditions: | | |
| | Auxiliary Contact , III-1, NO | | |
| | contact element (figure / form) | Figure 4e) / form Zb | |
| | contact polarity..... | - | |
| | utilization category (AC / DC)..... | AC-15 | |
| | rated operational voltage Ue (V) | 415V | |
| | rated operational current Ie (A) or power (kW) | 0,95A | |
| | Conditions, make/break operations: | | |
| | - test voltage U/Ue = 1,1 (V) | L1: 460 L2: - L3: - | P |
| | - power factor/time constant | L1: 0,30 L2: - L3: - | P |
| | - make operations: test current I/Ie=10 (A) | L1: 9,70 L2: - L3: - | P |
| | - break operations: test current I/Ie=10 (A) | L1: 9,70 L2: - L3: - | P |
| | - a.c. test: Inductor shunted by a resistor taking 3% of the total power consumed - d.c. test: test current increase from zero to steady-state value within limits of figure 9 | | |
| | - on-time (ms) | 68 | |
| | - operating cycles per minute | 6 | |
| | - number of operating cycles | 10 | P |
| | Behaviour and condition during and after the test: | | |
| | - no electrical or mechanical failures | | P |
| | - no contact welding or prolonged arcing | | P |
| | - no blowing of the fusible element in the earth circuit | | P |
| 8.3.3.5.6.b | Dielectric verification: | | |
| | dielectric test voltage (V) 2 xUe with min.of 1000V.. : | 1000V | P |

| IEC 60947-5-1 | | | |
|--------------------|---|----------------------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 8.3.3.5.4 | Making and breaking capacities of switching elements under abnormal conditions: | | |
| | Auxiliary Contact , III-1, NC | | |
| | contact element (figure / form) | Figure 4e) / form Zb | |
| | contact polarity..... | - | |
| | utilization category (AC / DC)..... | AC-15 | |
| | rated operational voltage Ue (V) | 415V | |
| | rated operational current Ie (A) or power (kW) | 0,95A | |
| | Conditions, make/break operations: | | |
| | - test voltage U/Ue = 1,1 (V) | L1: 460 L2: - L3: - | P |
| | - power factor/time constant | L1: 0,30 L2: - L3: - | P |
| | - make operations: test current I/Ie=10 (A) | L1: 9,70 L2: - L3: - | P |
| | - break operations: test current I/Ie=10 (A) | L1: 9,70 L2: - L3: - | P |
| | - a.c. test: Inductor shunted by a resistor taking 3% of the total power consumed - d.c. test: test current increase from zero to steady-state value within limits of figure 9 | | |
| | - on-time (ms) | 68 | |
| | - operating cycles per minute | 6 | |
| | - number of operating cycles | 10 | P |
| | Behaviour and condition during and after the test: | | |
| | - no electrical or mechanical failures | | P |
| | - no contact welding or prolonged arcing | | P |
| | - no blowing of the fusible element in the earth circuit | | P |
| 8.3.3.5.6.b | Dielectric verification: | | |
| | dielectric test voltage (V) 2 xUe with min.of 1000V.. : | 1000V | P |

| IEC 60947-5-1 | | | |
|---------------|--------------------|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |

| | | | |
|--|--|--|--|
| 8.3.1 | TEST SEQUENCE IV | | |
| Auxiliary Contact (NO), 1 sample: LT1-D9511 | | | |
| Test No. 1 | - Performance under conditional short-circuit current (8.3.4) | | |
| Test No. 2 | - Dielectric verification (8.3.3.5.6.b) | | |

| | | | |
|-------------|--|-----------------------------------|---|
| 8.3.4 | Performance under conditional short-circuit current | | |
| | contact element (figure / form) | Figure 4e) / form Zb | |
| | contact polarity..... | - | |
| | type of SCPD | Fuse, RT16-00, | |
| | ratings of SCPD (A / V) | 10A/500V | |
| | prospective current (kA) | 1kA | |
| | test voltage (V) U/Ue = 1,1 (V) | L1: 458 | P |
| | r.m.s. test current obtained (kA) | L1: 1,02 | P |
| | power factor (max. 0,7) | 0,67 | P |
| | Auxiliary Contact (NC) | IV-1 | |
| | first CO operation by closing the separate making switch: test I_p / I^2dt (A / A ² s) | L1: 426A / 0,223kA ² s | P |
| | time interval between test (min. 3 min) | 3 | P |
| | second CO operation by closing the separate making switch: test I_p / I^2dt (A / A ² s) | L1: 409A / 0,186kA ² s | P |
| | time interval between test (min. 3 min) | 3 | P |
| | third making operation to closed switching elements: test I_p / I^2dt (A / A ² s) | L1: 429A / 0,200kA ² s | P |
| 8.3.3.5.6.b | Dielectric verification: | | |
| | dielectric test voltage (V) 2 xUe with min.of 1000V.. | 1000V | P |

| | | | |
|--|---|-----------------------------------|---|
| 8.3.4 | Performance under conditional short-circuit current | | |
| Auxiliary Contact (NC), 1 sample: LT1-D9511 | | | |
| | contact element (figure / form) | Figure 4e) / form Zb | |
| | contact polarity..... | - | |
| | type of SCPD | Fuse, RT16-00, | |
| | ratings of SCPD (A / V) | 10A/500V | |
| | prospective current (kA) | 1kA | |
| | test voltage (V) U/Ue = 1,1 (V) | L1: 458 | P |
| | r.m.s. test current obtained (kA) | L1: 1,02 | P |
| | power factor (max. 0,7) | 0,67 | P |
| | Auxiliary Contact (NC) | IV-1 | |
| | first CO operation by closing the separate making switch: test I_p / I^2dt (A / A ² s) | L1: 411A / 0,233kA ² s | P |

| IEC 60947-5-1 | | | |
|---------------|---|-----------------------------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | time interval between test (min. 3 min) | 3 | P |
| | second CO operation by closing the separate making switch: test I_p / I^2dt (A / A ² s) | L1: 407A / 0,196kA ² s | P |
| | time interval between test (min. 3 min) | 3 | P |
| | third making operation to closed switching elements: test I_p / I^2dt (A / A ² s) | L1: 431A / 0,211kA ² s | P |
| 8.3.3.5.6.b | Dielectric verification: | | |
| | dielectric test voltage (V) 2 xU _e with min.of 1000V.. : | 1000V | P |
| 8.3.1 | TEST SEQUENCE V (sample No. 5) | | |
| Test No. 1 | - Degree of protection of enclosed control circuit-devices (Annex C of IEC 60947-1) | | |
| Test No. 2 | - Verification of actuation force or moment (8.2.5) | | |
| Annex C | Degree of protection of enclosed control circuit-devices | | |
| | The enclosed control circuit devices shall comply with the requirements of Annex C of IEC60947-1 | | N/A |
| 8.2.5 | Verification of actuation force or moment | | |
| | When required in 7.1.5.3, the minimum actuating force or moment shall be tested during sequence V of 8.3.1. The performance shall be as stated in 7.1.5.3 | | N/A |
| 7.1.5.3 | Actuating force (or moment) | | |
| | The force (or moment) required to operate the actuator shall be compatible with the intended application, taking into account the size of the actuator, the type of enclosure or panel, the environment of the installation and the use for which it is intended | | N/A |
| | The minimum starting force (or moment) shall be sufficiently large to prevent inadvertent operation; e.g. push-buttons and rotary switches to be used with enclosures complying with degrees of protection IPX5 or IPX6 shall not become actuated when hit by the jet of water applied during the test of the enclosed equipment. | | N/A |
| | Minimum force (N) | | N/A |
| | Minimum moment (Nm) | | N/A |

| IEC 60947-5-1 | | | |
|---------------|--------------------|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |

| | | | |
|-------------------------|---|--|--|
| 8.3.1. | TEST SEQUENCE VI | | |
| - 1 sample: VI-1 | | | |
| Test No. 1 | - Measurement of clearances and creepage distances (7.1.4 of IEC 60947-1) | | |
| Test No. 2 | - Verification of limitation of rotation of a rotary switch (8.2.6) | | |

| | | | |
|---------|---|------------------|-----|
| 7.1.4 | Measurement of clearances and creepage distances | | |
| | Clearances and creepage distances | See clause 7.1.4 | P |
| | Verification of limitation of rotation of a rotary switch (8.2.6) | | N/A |
| 8.2.6 | Verification of limitation of rotation of a rotary switch | | |
| | When this test is required in 7.1.4.5, it shall be tested during sequence VI of 8.3.1 The test sample shall be mounted according to the manufacturer's instructions | | N/A |
| 7.1.4.5 | Limitation of rotation (of a rotary switch) | | |
| | When actuators with limited or unidirectional movement are used, they shall be fitted with robust means of limitation, capable of withstanding five times the actual maximum actuating moment | | N/A |
| 8.2.6 | The operating moment shall be measured five times and the maximum value recorded (Nm) : | | N/A |
| | The maximum moment value, multiplied by five, shall be applied to the actuator by forcing it against the means of limitation. The moment shall be applied for 10 s (Nm)..... : | | N/A |
| | Means of limitation has not moved, become loose or prevented the actuator's normal operation | | N/A |

| IEC 60947-5-1 | | | |
|---------------|---|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 8.4 | TEST FOR EMC | | |
| 8.4.1. | General | | |
| | Control circuit devices having only passive components are not required to be tested. | | N/A |
| | Subclauses 8.3.2.1 of IEC 60947-1 and 8.3.2.4 of IEC 60947-1 apply with the following additions: | | |
| | Control circuit devices intended to be mounted in a hole of a panel shall be mounted in a hole which is located in the centre of a grounded square metal plate. | | N/A |
| | Control circuit devices intended to be mounted on surfaces or on standard rails shall be mounted directly on the grounded square metal plate or on the standard rail which is fixed on the grounded square metal plate. | | N/A |
| | Control circuit devices intended to be mounted in associated metal enclosures shall be mounted in the grounded metal enclosure with the smallest dimension available or on the grounded square metal plate, whichever configuration yields the worst results. | | N/A |
| | The dimension of the square metal plate shall be (300 ± 50) mm and the thickness $1,5 \text{ }_0^{+0,5}$ mm. | | N/A |
| | If not required otherwise by horizontal standard the connecting leads shall be $2 \text{ }_0^{+0,5}$ m. If the length of the connecting leads is other than 2 m. Cable length (m).....: | | N/A |
| | For control circuit devices not having integral cables, the type of cable or wire used shall be specified by the manufacturer: Type of cable.....: | | N/A |
| | The test sample shall be in the ON-status or in the OFF-status, whichever is the worse. Tested state : | ON / OFF | N/A |
| | Where a range of control circuit devices are made according to the same principle and design, and using the same type of components, tests may be performed on representative samples. | | N/A |
| 8.4.2 | Immunity | | |
| 8.4.2.1 | Electrostatic discharges. | | |
| | The test shall be performed according to IEC 61000-4-2 and 7.3.2.4, and shall be repeated 10 times at each measuring point, with a minimum time interval of 1 s between pulses. | See | N/A |
| 8.4.2.2 | Radiated radio-frequency electromagnetic fields | | |
| | The test shall be performed according to IEC 61000-4-3 and 7.3.2.5. | See | N/A |
| 8.4.2.3 | Electrical fast transients/bursts | | |
| | The test shall be performed according to IEC 61000-4-4 and 7.3.2.6, with all the connecting leads placed in the capacitive coupling clamp. | See | N/A |
| 8.4.2.4 | Surges | | |

| IEC 60947-5-1 | | | |
|---------------|--|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | The test shall be conducted using the methods of IEC 61000-4-5. Capacitive coupling shall be preferred. Surges shall be supplied between: | See | N/A |
| | a) between terminals intended to be connected to the power supply; | | N/A |
| | b) between each output terminal and each terminal intended to be connected to the power supply | | N/A |
| | The test voltage values are those of Table 8 but shall not exceed the corresponding U_{imp} value(s) given by the manufacturer following 7.2.3 of IEC 60947-1. Test voltages (V).....: | | N/A |
| | The repetition rate shall be one surge per minute, with the number of pulses being five positive and five negative. | | N/A |
| 8.4.2.5 | Conducted disturbances induced by radio-frequency fields | | |
| | The test shall be performed according to IEC 61000-4-6 and 7.3.2.8. | See | N/A |
| 8.4.2.6 | Power-frequency magnetic fields | | |
| | The test shall be performed according to IEC 61000-4-8 and 7.3.2.9. | See | N/A |
| 8.4.2.7 | Voltage dips and interruptions | | |
| | The test shall be performed according to IEC 61000-4-11 and 7.3.2.10. | See | N/A |
| 8.4.2 | Emission | | |
| | The test shall be performed according to CISPR 11, group 1, class A, and 7.3.3. | See | N/A |

| IEC 60947-5-1 | | | |
|---------------------------------------|---|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| Annex C of IEC 60947-1 | DEGREE OF PROTECTION OF ENCLOSED CONTROL CIRCUIT-DEVICES | | |
| Annex C | SPECIAL TESTS - DURABILITY TESTS | | |
| Annex F | CLASS II CONTROL CIRCUIT DEVICES INSULATED BY ENCAPSULATION REQUIREMENTS AND TESTS | | |
| Annex G | ADDITIONAL REQUIREMENTS FOR CONTROL CIRCUIT DEVICES WITH INTEGRALLY CONNECTED CABLES | | |
| Annex H | ADDITIONAL REQUIREMENTS FOR SEMICONDUCTOR SWITCHING ELEMENTS FOR CONTROL CIRCUIT DEVICES | | |
| Annex J | SPECIAL REQUIREMENTS FOR INDICATOR LIGHTS AND INDICATING TOWERS | | |
| Annex K | SPECIAL REQUIREMENTS FOR CONTROL SWITCHES WITH DIRECT OPENING ACTION | | |
| Annex L | SPECIAL REQUIREMENTS FOR MECHANICALLY LINKED CONTACT ELEMENTS | | |
| Annex M | TERMINAL MARKING, DISTINCTIVE NUMBER AND DISTINCTIVE LETTER FOR CONTROL CIRCUIT DEVICES | | |
| Annex N | Procedure to determine reliability data for electromechanical devices in control circuits used in functional safety applications | | |

IEC 60947-5-1

| TABLE: Clearance and Creepage Distance Measurements | | | | | | P |
|--|----------|--------|------------------|---------|-------------------|----------|
| clearance cl and creepage distance dcr at/of: | Uimp (V) | Ui (V) | required cl (mm) | cl (mm) | required dcr (mm) | dcr (mm) |
| Across the open contacts | 6kV | 690 | 5,5 | >8,0 | 10,0 | >15,0 |
| Between poles | 6kV | 690 | 5,5 | >8,0 | 10,0 | >15,0 |
| Between poles and accessible part | 6kV | 690 | 5,5 | >8,0 | 10,0 | >15,0 |
| supplementary information: | | | | | | |

| |
|----------------------|
| IEC 60947-5-1 |
|----------------------|

Photo of sample:

See reports: 180600074SHA-001, -002