



# Test Verification of Conformity

Verification Number: 180600074SHA-V1

On the basis of the referenced test report(s), sample(s) tested of the below product have been found to comply with the standards harmonized with the directives listed on this verification at the time the tests were carried out. Other standards and Directives may be relevant to the product. This verification is part of the full test report(s) and should be read in conjunction with it <them>.

Once compliance with all product relevant  mark directives are verified, including any relevant e.g. risk assessment and production control, the manufacturer may indicate compliance by signing a Declaration of Conformity themselves and applying the mark to products identical to the tested sample(s).

Applicant Name & Address:	Elmark Industries SC 2 Dobrudzha Blvd., Dobrich, BULGARIA
Manufacturing Site Name & Address:	Same as applicant
Product Description:	AC Contactor
Ratings & Principle Characteristics:	See appendix for detail
Models/Type References:	LT1-D4011, LT1-D5011, LT1-D6511, LT1-D8011, LT1-D9511
Brand Name(s):	
Standard(s)/Directive(s):	Low Voltage Directive 2014/35/EU EN 60947-4-1:2010 + A1: 2012 EN 60947-5-1: 2017
Verification Issuing Office Name & Address:	Intertek Testing Services Shanghai Building No.86, 1198 Qinzhou Road (North), Shanghai 200233, China
Test Report Number(s):	180600074SHA-001, -002, -003

  
Signature

Name: Oliver Wei  
Position: Manager  
Date: 24 October 2018

## APPENDIX: Test Verification of Conformity

This is an Appendix to Test Verification of Conformity Number: 180600074SHA-V1

Ratings & Principle  
Characteristics:

Type: LT1-D4011, LT1-D5011, LT1-D6511  
Ue= 415V~(3-poles), AC-3: Ie= 40(LT1-D4011), 50(LT1-D5011),  
65A(LT1-D6511); Us=415Vac;  
Ith= 60(LT1-D4011), 80A(LT1-D5011, LT1-D6511), Ir= 5kA, Iq=20kA  
Ui= 690V, Uimp= 6kV;

Type: LT1-D8011, LT1-D9511  
Ue= 415V~(3-poles), AC-3: Ie= 80(LT1-D8011), 95A(LT1-D9511);  
Us=415Vac;  
Ith= 125A, Ir= 5kA, Iq=20kA, Ui= 690V, Uimp= 6kV

Auxiliary circuit:  
Ith= 10A, Cat.: AC-15, Ue= 415V, Ie= 0,95A



Signature

Name: Oliver Wei

Position: Manager

Date: 24 October 2018

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.