




Ref. Certif. No.
SE-91897

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Moulded Case Circuit-Breakers
Name and address of the applicant	Elmark Industries SC 2 Dobrudzha Blvd., Dobrich, BULGARIA
Name and address of the manufacturer	Same as applicant
Name and address of the factory <i>Note: When more than one factory, please report on page 2</i>	Same as applicant
Ratings and principal characteristics	Ue=415V~(3P), In=400A, Ui=690V, Uimp=6kV, 50/60Hz, Cat. B Icu=65kA, Ics=42kA, Icw=5kA/1s
Trademark (if any)	
Customer's Testing Facility (CTF) Stage used	-
Model / Type Ref.	DS 1
Additional information (if necessary may also be reported on page 2)	-
A sample of the product was tested and found to be in conformity with	IEC 60947-2:2016
As shown in the Test Report Ref. No. which forms part of this Certificate	180600076SHA-001

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Box 1103
SE-164 22 Kista, Sweden
Int +46 8 750 00 00

Date: 13 September 2018

intertek

Signature: 
Fredrik Wennersten