

Certificate



Intertek

for European Product Safety

Reference No. 1815647

Moulded Case Circuit-Breakers

Type designation DS 1

Certificate holder **Elmark Industries SC**
2 Dobrudzha blvd., Dobrich,
BULGARIA

The product complies with the standard(s) EN 60947-2:2017

Date of expiry 13 September 2023

EU Directive information According to the principle of presumption of conformity, this certificate constitutes support for an EC Declaration of Conformity and CE marking according to the Low Voltage Directive 2014/35/EU.

Additional information in Appendix.

Certification Body Intertek Semko AB, Product Certification

Place Kista - Stockholm

Signed

Fredrik Wennersten

Date 13 September 2018


Page 1 of 2



Intertek
Appendix

Reference No. 1815647

Technical data


Type designation	DS 1
Rated voltage (V)	415V~
Rated current (A)	400A
BRAND name:	
Frequency (Hz)	50/60
IP-Class	IP20
Poles No.	3
Product information	Ui=690V, Uimp=6kV, 50/60Hz, Cat. B Icu=65kA, Ics=42kA, Icw=5kA/1s

Manufacturing site(s) Elmark Industries SC
2 Dobrudzha blvd., Dobrich, BULGARIA

According to the principle of presumption of conformity, this certificate, which includes production control, constitutes support for an EC Declaration of Conformity and CE marking according to the Low Voltage Directive 2014/35/EU.

This presumption can expire before end of validity of this certificate due to new issued Standard or Amendment and changes within the EU legislation.

Certification Body Intertek Semko AB, Product Certification *Place* Kista - Stockholm

Signed 
Fredrik Wennersten *Date* 13 September 2018

This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.