


Test Verification of Conformity

Verification Number: 180600077SHA-V1

On the basis of the referenced test report(s), sample(s) tested of the below product have been found to comply with the standards harmonized with the directives listed on this verification at the time the tests were carried out. Other standards and Directives may be relevant to the product. This verification is part of the full test report(s) and should be read in conjunction with it <them>.

Once compliance with all product relevant **CE** mark directives are verified, including any relevant e.g. risk assessment and production control, the manufacturer may indicate compliance by signing a Declaration of Conformity themselves and applying the mark to products identical to the tested sample(s).

Applicant Name & Address:	Elmark Industries SC 2 Dobrudzha blvd., Dobrich, BULGARIA
Manufacturing Site Name & Address:	Same as applicant
Product Description:	Moulded Case Circuit-Breakers
Ratings & Principle Characteristics:	Ue=415V~(3P), In=400A; Ui=690V, Uimp=6kV, 50/60Hz, Cat. B Icu=65kA, Ics=42kA, Icw=5kA/1s
Models/Type References:	DS 1
Brand Name(s):	
Standard(s)/Directive(s):	EN61543: 1995/+A11: 2003/+A12: 2005/+A2:2006 The EMC Directive 2014/30/EU
Verification Issuing Office Name & Address:	Intertek Testing Services Shanghai Building No.86, 1198 Qinzhou Road (North),Shanghai 200233, China
Test Report Number(s):	180600077SHA-001



Oliver Wei
Manager
19 November 2018