


IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR
ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE


Product	Residual current operated circuit-breakers without integral overcurrent protection for household and similar uses (RCCBs)
Name and address of the applicant	Elmark Industries SC 2 Dobrudzha Blvd., Dobrich, BULGARIA
Name and address of the manufacturer	Same as applicant
Name and address of the factory Note: When more than one factory, please report on page 2	Same as applicant
Ratings and principal characteristics	Un= 240V~(1P+N), 415V~(3P+N), 50/60Hz, switched neutral pole In= 10, 16, 20, 25, 32, 40, 63A; -25~40°C IΔn= 0,03, 0,1, 0,3A, type AC & type A Icn= IΔc= 6000A; IP20
Trademark (if any)	
Customer's Testing Facility (CTF) Stage used	-
Model / Type Ref.	JEL1
Additional information (if necessary may also be reported on page 2)	-
A sample of the product was tested and found to be in conformity with	IEC 61008-1:2010+A1+A2 IEC 61008-2-1:1990
As shown in the Test Report Ref. No. which forms part of this Certificate	180600072SHA-001

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Box 1103
SE-164 22 Kista, Sweden
Int +46 8 750 00 00

Date: 31 October 2018

intertek

Signature: 

Paul Klemets