




Ref. Certif. No.

SE-93063

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Moulded case circuit-breakers with motor protection
Name and address of the applicant	ELMARK INDUSTRIES SC 2 Dobrudzha blvd., Dobrich, Bulgaria
Name and address of the manufacturer	Same as applicant
Name and address of the factory <i>Note: When more than one factory, please report on page 2</i>	Same as applicant
Ratings and principal characteristics	Ue=415V (3P), Ui=690V, Uimp=6kV, Cat. A, Class: 10A
Trademark (if any)	
Customer's Testing Facility (CTF) Stage used	-
Model / Type Ref.	TM2-E*
Additional information (if necessary may also be reported on page 2)	See page 2
A sample of the product was tested and found to be in conformity with	IEC 60947-2:2016 IEC 60947-4-1:2009+A1
As shown in the Test Report Ref. No. which forms part of this Certificate	180600075SHA-001, -002


This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Box 1103
SE-164 22 Kista, Sweden
Int +46 8 750 00 00

Date: 17 January 2019



Signature:


Henrik Wikström

Additional information (if necessary)

Explanation of type designation TM2-E*:

The symbol "*" denote the rated current, including:

Code	In(A)	Code	In(A)
01	0,16	10	6,3
02	0,25	14	10
03	0,4	16	14
04	0,63	20	18
05	1	21	23
06	1,6	22	25
07	2,5	32	32
08	4		

Rated current In (A)	Adjustable Current (A)	415V	
		Icu (kA)	Ics (kA)
0,16	0,1~0,16	50	50
0,25	0,16~0,25	50	50
0,4	0,25~0,4	50	50
0,63	0,4~0,63	50	50
1	0,63~1	50	50
1,6	1~1,6	50	50
2,5	1,6~2,5	50	50
4	2,5~4	50	50
6,3	4~6,3	50	50
10	6~10	50	50
14	9~14	10	5
18	13~18	10	5
23	17~23	10	5
25	20~25	10	5
32	24~32	10	5

Date: 17 January 2019

Signature: 