

CERTIFICATE

No. Z2 117614 0001 Rev. 00

Holder of Certificate: **Resun Solar Energy Co., LTD**
Room 606, Building 13, Yongshang garden
Jinfeng road, Mudu town, Wuzhong district
215000 SuZhou City, Jiangsu Province
PEOPLE'S REPUBLIC OF CHINA

Certification Mark:



Product: **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**
Mono-Crystalline Silicon Photovoltaic Module

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 701262215501-00

Valid until: 2027-08-28

Date, 2022-08-31



(Zhulin Zhang)



CERTIFICATE

No. Z2 117614 0001 Rev. 00

Model(s):

RS9HxxxM (xxx=645-670, in steps of 5)
 RS9KxxxM (xxx=585-610, in steps of 5)
 RS9TxxxM (xxx=535-560, in steps of 5)
 RS9NxxxM (xxx=485-510, in steps of 5)
 RS9YxxxM (xxx=390-420, in steps of 5)
 RS8LxxxM (xxx=530-570, in steps of 5)
 RS8KxxxM (xxx=445-475, in steps of 5)
 RS8VxxxM (xxx=400-425, in steps of 5)
 xxx is standing for rated output power at STC.

Parameters:

Fire Safety Class:	Class C according to UL790.
Safety Class:	Class II
Max. System Voltage:	1500V DC
Test Laboratory:	Changzhou HuaYang Inspection and Testing Technology Co., Ltd. No.8 Lanxiang Road, Wujin Economic Development Zone Changzhou, Jiangsu, P.R.China
Construction:	Framed, with Junction box, cable and connector.

Tested according to:

IEC 61215-1:2016
 IEC 61215-1-1:2016
 IEC 61215-2:2016
 IEC 61730-1:2016
 IEC 61730-2:2016
 EN 61215-1:2016
 EN 61215-1-1:2016
 EN 61215-2:2017
 EN IEC 61730-1:2018
 EN IEC 61730-1:2018/AC:2018-06
 EN IEC 61730-2:2018
 EN IEC 61730-2:2018/AC:2018-06